

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Air conditioner outdoor unit

Name and address of the applicant

Daikin Europe N.V.
Zandvoordestraat 300
8400 OOSTENDE
Belgium

Name and address of the manufacturer

Daikin Europe N.V.
Zandvoordestraat 300
8400 OOSTENDE
Belgium

Name and address of the factory

*Note: When more than one factory, please report on page 2*Daikin Europe N.V.
Zandvoordestraat 300
8400 OOSTENDE
Belgium Additional information on page 2

Ratings and principal characteristics

50 Hz, class I, IPX4, refrigerant mass : R32 (3.4 kg)

type RXYSA4A7V1B: 220-240 Vac, 27 A
type RXYSA4A7Y1B: 380-415 Vac, 13.6 A
type RXYSA5A7V1B: 220-240 Vac, 27 A
type RXYSA5A7Y1B: 380-415 Vac, 13.6 A
type RXYSA6A7V1B: 220-240 Vac, 27 A
type RXYSA6A7Y1B: 380-415 Vac, 13.6 A

Trademark / Brand (if any)

DAIKIN

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

RXYSA4A7V1B, RXYSA4A7Y1B, RXYSA5A7V1B,
RXYSA5A7Y1B, RXYSA6A7V1B, RXYSA6A7Y1B

Additional information (if necessary may also be reported on page 2)

Re-issue of BE-9487 dated 2020-11-26 due to technical change. For details refer to test report.

 Additional information on page 2


A sample of the product was tested and found to be in conformity with

IEC 60335-1:2010, IEC 60335-1:2010/AMD1:2013, IEC 60335-1:2010/AMD2:2016, IEC 60335-2-40:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

630644.01, 630644.01 Amendment-1

This CB Test Certificate is issued by the National Certification Body

SGS Belgium N.V. – Division SGS-CEBEC
Riverside Business Park
Bld Internationaalelaan 55
Build. A
BRUSSELS 1070
Belgium

Signature: Calogero Lana



Date: 2023-07-13