

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Air conditioner outdoor unit

Name and address of the applicant

Daikin Europe N.V.
Zandvoordestraat 300, 8400 OOSTENDE
Belgium

Name and address of the manufacturer

Daikin Europe N.V.
Zandvoordestraat 300, 8400 OOSTENDE
Belgium

Name and address of the factory

Daikin Europe N.V.
Zandvoordestraat 300, 8400 OOSTENDE
Belgium*Note: When more than one factory, please report on page 2* Additional information on page 2

Ratings and principal characteristics

50 Hz, 380-415 V, class I, IP14B, refrigerant mass : R32

RXYA10A7Y1B: 22 A
RXYA12A7Y1B: 24 A
RXYA14A7Y1B: 27 A
RXYA16A7Y1B: 31 A
RXYA18A7Y1B: 35 A
RXYA20A7Y1B: 42 A
RXYA8A7Y1B: 16.1 A
RYMA5A7Y1B: 15 A

Trademark / Brand (if any)

Daikin

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

RXYA10A7Y1B, RXYA12A7Y1B, RXYA14A7Y1B, RXYA16A7Y1B,
RXYA18A7Y1B, RXYA20A7Y1B, RXYA8A7Y1B, RYMA5A7Y1B

Additional information (if necessary may also be reported on page 2)

 Additional information on page 2


A sample of the product was tested and found to be in conformity with

IEC 60335-1:2010, IEC 60335-1:2010/AMD1:2013, IEC 60335-1:2010/
AMD2:2016, IEC 60335-2-40:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

634005.01

This CB Test Certificate is issued by the National Certification Body

SGS Belgium N.V. – Division SGS-CEBEC
Riverside Business Park , Bld Internationelelaan 55 , Build. A
BRUSSELS 1070
Belgium

Date: 2024-02-19

Signature: Calogero Lana