

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Air conditioner outdoor unit

Name and address of the applicant

Daikin Europe N.V.
Zandvoordestraat 300, 8400 OOSTENDE
Belgium

Name and address of the manufacturer

Daikin Europe N.V.
Zandvoordestraat 300, 8400 OOSTENDE
Belgium

Name and address of the factory

*Note: When more than one factory, please report on page 2*DAIKIN AIR-CONDITIONING (SUZHOU) CO., LTD.
No.578, Zhongxin Avenue East, Suzhou Industrial Park
Jiangsu Province, 215126
China☐ [Additional information on page 2](#)

Ratings and principal characteristics

380-415 V/400 V 3N, 50/60 Hz, class I, IP14B, refrigerant mass: R32

ERA200AMYFB: 18.5 A
ERA250AMYFB: 22 A
ERA300AMYFB: 24 A
RXYS10AMY1B: 22 A
RXYS12AMY1B: 24 A
RXYS8AMY1B: 18.5 A

Trademark / Brand (if any)

DAIKIN

Customer's Testing Facility (CTF) Stage used

CTF Stage 2

Model / Type Ref.

ERA200AMYFB, ERA250AMYFB, ERA300AMYFB, RXYS10AMY1B,
RXYS12AMY1B, RXYS8AMY1B

Additional information (if necessary may also be reported on page 2)

☐ [Additional information on page 2](#)


A sample of the product was tested and found to be in conformity with

IEC 60335-1:2010, IEC 60335-1:2010/AMD1:2013, IEC 60335-1:2010/
AMD2:2016, IEC 60335-2-40:2022

As shown in the Test Report Ref. No. which forms part of this Certificate

630644.04

This CB Test Certificate is issued by the National Certification Body

SGS Belgium N.V. – Division SGS-CEBEC
Riverside Business Park, Bld Internationalelaan 55, Build. A
BRUSSELS 1070
Belgium

Signature: Calogero Lana



Date: 2024-04-25